

## TEST CERTIFICATE

Certificate Number: TC/00/09/01/C2 Original date of issue: 07 September 2000

Report Numbers: 343 PCT & IFCA/00161 Date of test: April 2000- June 2000

This is to certify that samples of: **D-1554-BC Overhead Door Closer**

Manufactured by: **Ryobi Ltd**

have been successfully type tested according to:

**EN 1154: 1997 - Building hardware - Controlled door closing devices -  
Requirements and test methods**

Classification:

3	8	4	1	1	3
---	---	---	---	---	---

by the examination and application of the performance tests for :-

5.1	Product information
5.2.2	Durability
5.2.3	Closing moment
5.2.4	Opening moment
5.2.5	Efficiency
5.2.6	Closing time
5.2.7	Angles of operation
5.2.8	Overload
5.2.9	Temperature
5.2.10	Fluid leakage
5.2.11	Damage
5.2.17	Corrosion resistance
8	Marking

and the additional performance tests for :-

5.2.12	Latch control
5.2.13	Backcheck
5.2.18	Additional requirements for fire door closers

for and on behalf of :- APT Laboratories Ltd

Issued by



Date

11.9.00

Authorised by



Date

11-9-00

© APT Laboratories Ltd 1998