

APT LABORATORIES LTD

Mechanical, Performance, Environmental and Safety Testing



TEST CERTIFICATE

Certificate Number: **TC/00/04/01/C2** Original date of issue: **03/04/00**
Report Numbers: **248 PCT and IFCA 00123** Date of test: **Oct - Dec 1999**

This is to certify that samples of: **Ryobi D-2550 Overhead door closers**

Manufactured by: **Ryobi Limited**

have been successfully type tested according to:

EN 1154: 1996 - Building hardware - Controlled door closing devices - Requirements and test methods

Classification:

4	8	4 1	1	1	3
---	---	--------	---	---	---

by the examination and application of the performance tests for :-

5.1	Product information
5.2.2	Durability
5.2.3	Closing moment
5.2.4	Opening moment
5.2.5	Efficiency
5.2.6	Closing time
5.2.7	Angles of operation
5.2.8	Overload
5.2.9	Temperature
5.2.10	Fluid leakage
5.2.11	Damage
5.2.17	Corrosion resistance
8	Marking

and the additional performance tests for :-

5.2.12	Latch control
5.2.13	Backcheck
5.2.15	Adjustable closing force
5.2.18	Additional requirements for fire doors

for and on behalf of :- **APT Laboratories Ltd**

Issued by

Date

3-4-00

Authorised by

Date

3-7-00

© APT Laboratories Ltd 1998